



ADDENDA NO. 2

This addenda consists of 2 pages

TO: All Packet Holders

FROM: City of Kenai Public Works Department

DATE: February 15, 2023

SUBJECT: Proposal Quote Request (PQR) – 2023 Softball Green Strip Playground Equipment

DUE DATE: **February 21, 2023 by 12:00pm**

Proposers must acknowledge receipt of this Addenda within their proposals. Failure to do so may result in the disqualification or rejection of the proposal.

Note: Information in this addendum takes precedence over original information. All other provisions of the document remain unchanged.

01-01 Question: Site security Temporary fencing and posting of installation area. Will the city have fencing around the area, or is this the responsibility of the contractor to be included in the bid?

Response: The City is not requiring installation of security or construction type temporary fencing. The Parks Department will post signage that the area is closed while under construction. Any pier holes shall be protected by Contractor until concrete is poured. Contractor may install temporary fencing at their discretion if they would prefer to.

01-02 Question: What is the common frost upheaval depth for Kenai in the area of proposed installation. Will there be a requirement for increased footing depths due to upheaval? Standard footing depths for General Use Play equipment range from 18" to 36" depending upon event and surfacing used.

Response: The City of Kenai has a building code frost depth of 42". Any permanent foundation elements of the playground equipment shall have piers that meet this minimum depth to prevent upheaving, at the cost of the contractor.

End of Addenda 2