

**ADDENDUM NO. 1**

**This addenda consists of 2 pages**

**TO:** All Packet Holders

**FROM:** City of Kenai Public Works Department

**DATE:** August 3, 2023

**SUBJECT:** 2023 Cemetery Phase 2 Fencing

**DUE DATE:** August 9<sup>th</sup>, 2023, no later than 10:00am

---

**Proposers must acknowledge receipt of this Addenda within their proposals. Failure to do so may result in the disqualification or rejection of the proposal.**

Note: Information in this addendum takes precedence over original information. All other provisions of the document remain unchanged.

01-01 Plan Holder Question: I'd like to submit a request for fence substitution for this project.

See attached document with cut sheets and additional product information. We can supply the **Omega II Classic**, which is the fence design from which Ameristar created their "montage plus" as a match. If you prefer to have the appearance provided by a tube steel top rail, we can add it to the Classic design by welding it on prior to powder coating for a seamless look. See an example on page 7 (sheet 156) where it is used on the Classic gate.

**Response: Unfortunately the Omega II Classic does not meet the comparable standards of the Ameristar Montage Plus fencing as specified. The Ameristar Montage Plus was selected as the closest comparable we could find to match the existing older cemetery fence, with the only exception that we did not want spiked tips due to concerns with impaling moose. We are looking for tube steel pickets, not wire. The wire mesh panels are much less substantial, smaller diameter, and too far away appearance wise from the desired look. Product does appear to be well made, and may be suitable for other fence projects within the City, but not this project.**

01-02 Plan Holder Question: SCOPE OF WORK

"Submit similar product for approval "during bid phase", please define, before closing of bid, before close of questions?"

**Response:** All requests for substitutions are to be submitted by the last day for questions, so if a substitution request is granted, it will be responded to via addendum so all bidders know that an alternate product is also acceptable to Owner prior to bids being submitted.

***End of Addendum 1***