



KENAI

City of Kenai | 210 Fidalgo Ave, Kenai, AK 99611-7794 | 907.283.7535 | www.kenai.city

ADDENDUM NO. 1

This addendum consists of 1 page

TO: All Bid Packet Holders
FROM: City of Kenai Public Works Department
DATE: March 20, 2024
SUBJECT: Invitation to Bid – Public Safety Building Tower Guy System Upgrade
DUE DATE: ***March 26, 2024, by no later than 2:00 PM***

Bidders must acknowledge receipt of this Addendum in the appropriate place on the Bid Form. Failure to do so may result in the disqualification or rejection of the bid.

Note: Information in this addendum takes precedence over original information. All other provisions of the document remain unchanged.

01-01 Plan Holder Question –

“What are the guy wire sizes?”

Response: Guy wires attached to the 105’ elevation shall be galvanized 7/16” 1x7 EHS, wires attached to the 73’ and 45’ elevations shall be galvanized 5/16” 1x7.

01-02 Plan Holder Question –

“How are guy wires attached to tower? There is no detail?”

Response: All guy system connection hardware shall be sized appropriately per specified wire sizing. Contractor shall provide a submittal for engineer approval of all guy system connections.

End of Addendum 1